

TEST RESULTS

Alternative Technologies, Inc.

12350 River Ridge Blvd.

Burnsville, MN 55337

Telephone (800) 255-8656 or (952) 894-3455

PCB CONTENT USEPA METHOD 8082

Report Date: 12-Sep-13

Date Received: 12-Sep-13

SAMPLE IDENTIFICATION		LABORATORY NUMBER	AROCLORE	RESULTS
S/N: 7000433	KV1A-A 1 WESTINGHOUSE	177941-001		<1 ppm
CO#: MOBT-6	ARCHER SUB			
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

Alternative Technologies, Inc., (ATI) shall assume no liability or responsibility,
nor imply or express any warranty or other security against
client loss of production, operation, profitability, or other loss,
regardless of circumstances, beyond the cost of re-analysis by ATI.

Rpt ID: 46878-1/1

Approved by: _____

[Signature]